

Document of Certification

Mechanical Testing Services, Inc.

certifies that

Oliver Healthcare Packaging

Laminar Flow Hood 09146

has been tested in accordance with *TEST-RP-CC006.3 Recommended Testing Procedures to demonstrate compliance with the ISO Standard 14644-1:2015.*

Area meets criteria for ISO Class 5 Cleanroom Facility.

IN WITNESS WHERE OF, the undersigned has executed the certification this

30th day of August, 2022

Certification expires 400 days from above executed date.

Signature



Robert VanDenBrink

Title NEBB CPT Certified Professional

Mechanical Testing Services, Inc.
4275 Spartan Industrial Dr., S.W., Suite B
Grandville, Michigan 49418-2503
616-224-7044

Document of Certification

Mechanical Testing Services, Inc.

certifies that

Oliver Healthcare Packaging

Laminar Flow Hood 09616

has been tested in accordance with *TEST-RP-CC006.3 Recommended Testing Procedures to demonstrate compliance with the ISO Standard 14644-1:2015.*

Area meets criteria for ISO Class 5 Cleanroom Facility.

IN WITNESS WHERE OF, the undersigned has executed the certification this

30th day of August, 2022

Certification expires 400 days from above executed date.

Signature



Robert VanDenBrink

Title NEBB CPT Certified Professional

Mechanical Testing Services, Inc.
4275 Spartan Industrial Dr., S.W., Suite B
Grandville, Michigan 49418-2503
616-224-7044