

# *Certificate of Performance*

*On this date the cleanroom facilities of*  
***Oliver Healthcare Packaging Company***  
***915 Pennsylvania Boulevard***  
***Feasterville, PA 19053***

*Have been tested in accordance with NEBB Procedural Standards for  
Certified Testing of Cleanrooms to meet the following air cleanliness classification  
requirements of International Standard ISO 14644-1:2015 during the occupancy state noted.*

*Zone #8 Hand Assembly/Inspection - ISO Class 7 at 0.5, 1.0 & 5.0  $\mu\text{m}$  – At-Rest*

*Zone #8 Hand Assembly/Inspection - ISO Class 7 at 0.5, 1.0 & 5.0  $\mu\text{m}$  – Operational*

*Zone #7 Gowning, Zone #9 Sheet Feed, Zone #10 Wash-Up/Storage - ISO Class 8 at 0.5, 1.0 & 5.0  $\mu\text{m}$  – At-Rest*

*Zone #7 Gowning, Zone #9 Sheet Feed, Zone #10 Wash-Up/Storage - ISO Class 8 at 0.5, 1.0 & 5.0  $\mu\text{m}$  – Operational*


*NEBB Certified Firm: Air Filtration Management*

*Phone: (610) 867-3869*

*[www.airfiltrationmgmt.com](http://www.airfiltrationmgmt.com)*

*NEBB Certification Number: 3898*

*NEBB CPT Professional: Michael J. Kelly*

*Signature: *

*Test Date: Jan 2025 Retest Date: Jan 2026*

**National Environmental Balancing Bureau**

