

Certificate of Performance

On this date the cleanroom facilities of

Oliver Healthcare Packaging Building 2

915 Pennsylvania Boulevard

Feasterville, PA 19053

Have been tested in accordance with NEBB Procedural Standards for Certified Testing of Cleanrooms to meet the following air cleanliness classification requirements of International Standard ISO 14644-1:2015 during the occupancy state noted.

Zone #11 Gowning Area - ISO Class 8 at 0.5, 1.0 & 5.0 μm – At-Rest

Zone #11 Gowning Area - ISO Class 8 at 0.5, 1.0 & 5.0 μm – Operational

Zone #12 Pouch Manufacturing Area - ISO Class 8 at 0.5, 1.0 & 5.0 μm – At-Rest

Zone #12 Pouch Manufacturing Area - ISO Class 8 at 0.5, 1.0 & 5.0 μm – Operational

NEBB Certified Firm: Air Filtration Management, Inc.

Phone: (610) 867-3869

www.airfiltrationmgmt.com

NEBB Certification Number: 3898

NEBB CPT Professional: Michael J. Kelly

Signature: 

Test Date: June 2024 Retest Date: June 2025

National Environmental Balancing Bureau

