

Certificate of Performance

On this date the cleanroom facilities of

*Oliver Healthcare Packaging Building 2
915 Pennsylvania Boulevard
Feasterville, PA 19053*

*Have been tested in accordance with NEBB Procedural Standards for
Certified Testing of Cleanrooms to meet the following air cleanliness classification
requirements of International Standard ISO 14644-1:2015 during the occupancy state noted.*

Zone #11 Gowning Area - ISO Class 8 at 0.5, 1.0 & 5.0 μm – At-Rest

Zone #11 Gowning Area - ISO Class 8 at 0.5, 1.0 & 5.0 μm – Operational

Zone #12 Pouch Manufacturing Area - ISO Class 8 at 0.5, 1.0 & 5.0 μm – At-Rest

Zone #12 Pouch Manufacturing Area - ISO Class 8 at 0.5, 1.0 & 5.0 μm – Operational


NEBB Certified Firm: Air Filtration Management, Inc.

Phone: (610) 867-3869

www.airfiltrationmgmt.com

NEBB Certification Number: 104

NEBB CPT Professional: Michael J. Kelly

Signature: 

Test Date: June 2020 Retest Date: June 2021

National Environmental Balancing Bureau

