

# *Certificate of Performance*

*On this date the cleanroom facilities of  
Oliver Healthcare Packaging  
905 Pennsylvania Boulevard  
Feasterville, PA 19053*

*Have been tested in accordance with NEBB Procedural Standards for  
Certified Testing of Cleanrooms to meet the following air cleanliness classification  
requirements of International Standard ISO 14644-1:2015 during the occupancy state noted.*

*Zone #6 Cleanroom - ISO Class 8 at 0.5, 1.0 & 5.0  $\mu\text{m}$  – At-Rest  
Zone #6 Cleanroom - ISO Class 8 at 0.5, 1.0 & 5.0  $\mu\text{m}$  – Operational  
Zone #6 Gowning Area - ISO Class 8 at 0.5, 1.0 & 5.0  $\mu\text{m}$  – At-Rest  
Zone #6 Gowning Area - ISO Class 8 at 0.5, 1.0 & 5.0  $\mu\text{m}$  – Operational*

*NEBB Certified Firm: Air Filtration Management, Inc.*

*Phone: (610) 867-3869*

*[www.airfiltrationmgmt.com](http://www.airfiltrationmgmt.com)*

*NEBB Certification Number: 104*

*NEBB CPT Professional: William M. Bock*

*Signature: William M. Bock*

*Test Date: July 2019 Retest Date: July 2020*

**National Environmental Balancing Bureau**

