

## Certificate of compliance Cleanroom

Herewith The Baker Compagny B.V. declares that all measurements are executed in accordance to protocols resulting from NEN-EN-ISO 14644-1:2015 and meet the acceptance criteria.

**Customer:**

Oliver™ Healthcare Packaging  
Spurkt 1  
5804 AR Venray

**Measurements executed by:**

CleanAir by Baker  
Krommewetering 41  
3543 AP Utrecht

**Date of measurements:**

22 November 2019

**Certificate valid until:**

22 November 2020

**Location of measurements:**

Cleanroom 1

**Report number:**

19-4056732-1.1 Validation Cleanroom


**Tests executed:**

- Room classification "At rest"
- Room classification "In Operation"

**Result:**

Comply to ISO class 7  
Comply to ISO class 8

Sign CleanAir by Baker



D. Driesen  
Teamleader Service & Validation