

Certificate of Performance

On this date the cleanroom facilities of

Oliver Healthcare Packaging

905 Pennsylvania Boulevard

Feasterville, PA 19053

Have been tested in accordance with NEBB Procedural Standards for Certified Testing of Cleanrooms to meet the following air cleanliness classification requirements of International Standard ISO 14644-1:2015 during the occupancy state noted.

Zone #6 Cleanroom - ISO Class 8 at 0.5, 1.0 & 5.0 μm – At-Rest

Zone #6 Cleanroom - ISO Class 8 at 0.5, 1.0 & 5.0 μm – Operational

Zone #6 Gowning Area - ISO Class 8 at 0.5, 1.0 & 5.0 μm – At-Rest

Zone #6 Gowning Area - ISO Class 8 at 0.5, 1.0 & 5.0 μm – Operational

NEBB Certified Firm: Air Filtration Management, Inc.

Phone: (610) 867-3869

www.airfiltrationmgmt.com

NEBB Certification Number: 104

NEBB CPT Professional: William M. Bock

Signature: William M. Bock

Test Date: July 2018 Retest Date: July 2019

National Environmental Balancing Bureau

