

Certificate of compliance Cleanroom

Herewith The Baker Compagny B.V. declares that all measurements are executed in accordance to protocols resulting from NEN-EN-ISO 14644-1:2015 and meet the acceptance criteria.

Customer:

Oliver™ Healthcare Packaging
Spurkt 1
5804 AR Venray

Measurements executed by:

CleanAir by Baker
Krommewetering 41
3543 AP Utrecht

Date of measurements:

07 December 2018

Certificate valid until:

07 December 2019

Location of measurements:

Cleanroom 1

Report number:

18-4055612-1.1 Validation Cleanroom

Tests executed:

- Room classification "At rest"
- Room classification "In Operation"

Result:

Comply to ISO class 7
Comply to ISO class 8

Sign CleanAir by Baker

D. Driesen
Teamleader Service & Validation