AERO-DYNAMIEK

CERTIFICATE

Oliver Healthcare Packaging
Spurkt 1
5804 AR Venray

Cleanroom 2 is within compliance:

- **NEN-EN-ISO 14644-1:2016**
- **ISO Class 7 in 'at-rest' occupancy**
- **ISO Class 8 in operational occupancy**

The performed measurements:

- In accordance with NEN-EN-ISO 14644:1-2016
- In accordance with NEN-EN-ISO 14644:3-2019
- Executed by certified technical specialist
- Have been documented in report QAN0005257

Execution date: *30th of October 2026*
Expiration date : *30th of October 2027*

Qualification Company:

Aero-Dynamiek b.v.
Databankweg 7
3821 AL Amersfoort



J. Volkerink,
Technical Specialist.